



NSW RURAL FIRE SERVICE

Department of Planning and Environment (Parramatta)
Locked Bag 5022,
PARRAMATTA NSW 2124
Australia

Your reference: SSD-10101987
Our reference: DA20221013011140-Original-1

ATTENTION: Shaun Williams

Date: Wednesday 23 November 2022

Dear Sir/Madam,

Development Application

Other - Other Assessment - Commercial Premises

Response to Submissions - Kemps Creek Data Centre - 706-769 Mamre road Kemps Creek NSW, Lots X & Y DP421633 and Lot 22 DP258414

I refer to your correspondence dated 11/10/2022 seeking advice regarding bush fire protection for the above Development Application.

The New South Wales Rural Fire Service (NSW RFS) has reviewed the information provided and advises the following:

An updated bush fire report should be prepared to consider the latest architectural plans, such as any changes in asset protection zone (APZ) setbacks and location of the exposed generators.

If additional information is not received within 21 days the application will be refused on the basis of Requested Information not provided. A formal request for re-assessment would be required after this time.

For any queries regarding this correspondence, please contact Simon Derevnin on 1300 NSW RFS.

Yours sincerely,

Kalpana Varghese
**Supervisor Development Assessment & Plan
Built & Natural Environment**

Postal address

NSW Rural Fire Service
Locked Bag 17
GRANVILLE NSW 2142

Street address

NSW Rural Fire Service
4 Murray Rose Ave
SYDNEY OLYMPIC PARK NSW 2127

T (02) 8741 5555
F (02) 8741 5550
www.rfs.nsw.gov.au